SHREYAS ANISH SHAH
B.E.(Civil), PGPFMB
Mobile 9552306999 E.mail : shreyash.shaha@gmail.com

Form No. 2A
ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

Date: 05/01/2024

To,
SURATNA INFRA LLP,
468, Arihant Plaza, Bahinabai Garden Square, Jillha Peth Jalgaon-425001

Subject: Certificate for quality of materials used and quality of Construction and workmanship for the work of "**Sukruti Suratna**" having MahaRERA Registration Number **P49900052357** being developed by **Suratna Infra LLP.**

Sir,
I / We **Shreyas Shah** have undertaken an assignment of supervision of this real estate project.

Our Responsibility

I/We are responsible for carrying out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

Input Materials, Fixtures and Fittings

I/We hereby certify that all Construction material, Fixtures and Fittings with regard to the flooring, Electrical. Sanitary fittings etc. and amenities to be provided by the Promoter in the said Project, building and the Apartment as are as per specifications mentioned in Annexure 'F', of Agreement of Sale
For those items, where no specifications have been mentioned in agreement of sale, the materials, Fixtures and Fittings used conform to the relevant BIS Standards / IS /National Building codes or as per industry standards.

Workmanship

I/we hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

Structural Engineer-

Promoters has engaged structural engineer **Mr. Mohti Patil having JCMC License no.28 & having office at Unity Chamber, Ganesh Colony Jalgaon having cell no 9967144499**. The structural design of buildings in this project has been done under his supervision. The formwork and concrete mix design has been done as per IS 10262:2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record

Preservation of records

Records of all test results of this project have been properly kept in the prescribed formats and will be preserved at least up to the defect liability period or for the period as required by any other provision of law. We have attached the records of material as well as concrete testing along with this letter for your pursual.

Please specify deviation in quality of materials or any other item of work which were not conforming to the specifications as mentioned in Agreement of Sale – NA

Your Faithfully,

Signature of Engineer
Name : M/S SHREYAS SHAH
Qualification : B.E Civil (University of Pune)
Phone No. : 7020118705
Place : Jalgaon

Agreed and Accepted by:

Signature of Promoter
Name : Mr. Anish C. Shah
Date: 05/01/2024

SURATNA INFRA LLP
PARTNER

Scanned with CamScanner

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com

Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/02/2024 Date:- - 4 JAN 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 02/01/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	05/12/2023	02/01/2024	291	12.93
2	-----do----	--do--	--do--	351	15.60
3	-----do----	--do--	--do--	255	11.33

The consolidated testing charges amounting to Rs.260/- + GST Rs: 48/- have been received in cash.
From: M/s Suratna Infra LLP.,Jalgaon.
Vide receipt No: 8860807 Dated : 02/01/2024

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/488/2023 Date:- 22 DEC 2023

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 21/12/2023

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	07/12/2023	21/12/2023	264	11.73
2	-----do----	--do--	--do--	257	11.42
3	-----do----	--do--	--do--	242	10.76

The consolidated testing charges amounting to Rs.260/- + GST Rs: 48/- have been received in cash.
From: M/s Suratna Infra LLP,,Jalgaon.
Vide receipt No: 8860793 Dated : 21/12/2023

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/489/2023 Date:- 26 DEC 2023

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 22/12/2023

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	08/12/2023	22/12/2023	232	10.31
2	-----do----	--do--	--do--	253	11.24
3	-----do----	--do--	--do--	241	10.71

The consolidated testing charges amounting to Rs.260/- + GST Rs: 48/- have been received in cash.
From: M/s Suratna Infra LLP,,Jalgaon.
Vide receipt No: 8860794 Dated : 22/12/2023

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC ★ JALGAON ★

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

14 days

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/483/2023 Date:- 19 DEC 2023

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 19/12/2023

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	05/12/2023	19/12/2023	272	12.09
2	-----do----	--do--	--do--	246	10.93
3	-----do----	--do--	--do--	280	12.44

The consolidated testing charges amounting to Rs.260/- + GST Rs: 48/- have been received in cash.
From: M/s Suratna Infra LLP,,Jalgaon.
Vide receipt No: 8860788 Dated : 19/12/2023

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/466/2023 Date:- 16 DEC 2023

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 05/12/2023

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	28/11/2023	05/12/2023	231	10.27
2	-----do----	--do--	--do--	214	9.51
3	-----do----	--do--	--do--	241	10.71

The testing charges amounting to Rs.260/- + GST Rs: 48/- have been received in cash.
From: M/s Suratna Infra LLP,,Jalgaon.
Vide receipt No: 8860768 Dated : 05/12/2023

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon