SHREYAS ANISH SHAH
B.E.(Civil), PGPFMB
Mobile 9552306999 E.mail : shreyash.shaha@gmail.com

Form No. 2A
ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

Date: 05/04/2024

To,
SURATNA INFRA LLP,
468, Arihant Plaza, Bahinabai Garden Square, Jillha Peth Jalgaon-425001

Subject: Certificate for quality of materials used and quality of Construction and workmanship for the work of **"Sukruti Suratna"** having MahaRERA Registration Number **P49900052357** being developed by **Suratna Infra LLP.**

Sir,
I / We **Shreyas Shah** have undertaken an assignment of supervision of this real estate project.

Our Responsibility

I/We are responsible **for** carrying out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

Input Materials, Fixtures and Fittings

I/We hereby certify that all Construction material, Fixtures and Fittings with regard to the flooring, Electrical. Sanitary fittings etc. and amenities to be provided by the Promoter in the said Project, building and the Apartment as arc as per specifications mentioned in Annexure 'F', of Agreement of Sale
For those items, where no specifications have been mentioned in agreement of sale, the materials, Fixtures and Fittings used conform to the relevant BIS Standards / IS /National Building codes or as per industry standards.

Workmanship

I/we hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

Structural Engineer-

Promoters has engaged structural engineer **Mr. Mohti Patil having JCMC License no.28 & having office at Unity Chamber, Ganesh Colony Jalgaon having cell no 9967144499**. The structural design of buildings in this project has been done under his supervision. The formwork and concrete mix design has been done as per IS 10262:2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record

Preservation of records

Records of all test results of this project have been properly kept in the prescribed formats and will be preserved at least up to the defect liability period or for the period as required by any other provision of law. We have attached the records of material as well as concrete testing along with this letter for your pursual.

Please specify deviation in quality of materials or any other item of work which were not conforming to the specifications as mentioned in Agreement of Sale – NA

Your Faithfully,

Signature of Engineer
Name : M/S SHREYAS SHAH
Qualification : B.E Civil (University of Pune)
Phone No. : 7020118705
Place : Jalgaon

Agreed and Accepted by:

Signature of Promoter
Name: Mr.Anish C.Shah
Date: 05/04/2024

SURATNA INFRA LLP

PARTNER

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/47/2024 Date:- 29 JAN 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 25/01/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	10/01/2024	25/01/2024	354	15.73
2	-----do----	--do--	--do--	213	9.47
3	-----do----	--do--	--do--	334	14.84

The Testing Charges amounting to Rs.260/- + GST Rs: 48/- have been received in cash.
From: M/s Suratna Infra LLP,,Jalgaon.
Vide receipt No: 8860860 Dated : 25/01/2024

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/46/2024 Date:- 29 JAN 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 25/01/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	28/12/2023	25/01/2024	299	13.29
2	-----do----	--do--	--do--	290	12.89
3	-----do----	--do--	--do--	307	13.64

The Testing Charges amounting to Rs.260/- + GST Rs: 48/- have been received in cash.
From: M/s Suratna Infra LLP,,Jalgaon.
Vide receipt No: 8860859 Dated : 25/01/2024

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/91-B/2024 Date:- 21 FEB 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 20/02/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	10/02/2024	20/02/2024	275	12.22

The Consolidated Testing Charges amounting to Rs.620/- + GST Rs:112/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8860912 Dated : 20/02/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/91-A/2024 Date:- 21 FEB 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 20/02/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	03/02/2024	20/02/2024	423	18.80
2	-----do----	--do--	--do--	361	16.04
3	-----do----	--do--	--do--	364	16.18

The Consolidated Testing Charges amounting to Rs.620/- + GST Rs:112/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8860912 Dated : 20/02/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC ★ JALGAON ★

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/77/2024 Date:- 13 FEB 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 12/02/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	13/01/2024	12/02/2024	499	22.18
2	-----do----	--do--	--do--	363	16.13
3	-----do----	--do--	--do--	334	14.84

The Testing Charges amounting to Rs.260/- + GST Rs: 48/- have been received in cash.
From: M/s Suratna Infra LLP,,Jalgaon.
Vide receipt No: 8860897 Dated : 12/02/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/72/2024 Date:- 12 FEB 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 09/02/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	11/01/2024	09/02/2024	621	27.60
2	-----do----	--do--	--do--	384	17.07
3	-----do----	--do--	--do--	508	22.58

The Testing Charges amounting to Rs.260/- + GST Rs: 48/- have been received in cash.
From: M/s Suratna Infra LLP,,Jalgaon.
Vide receipt No: 8860892 Dated : 09/02/2024

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/106/2024 Date:- 26 FEB 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 20/02/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	10/02/2024	23/02/2024	354	15.73

The Testing Charges amounting to Rs.100/- + GST Rs:18/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8860914 Dated : 20/02/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/105/2024 Date:- 26 FEB 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 20/02/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	26/01/2024	23/02/2024	382	16.98
2	-----do----	--do--	--do--	247	10.98
3	-----do----	--do--	--do--	433	19.24

The Testing Charges amounting to Rs.260/- + GST Rs:48/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8860913 Dated : 20/02/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

TEST CERTIFICATE FOR ISI SHREE OM 500 TMT (QST) BARS

SRJ
WORLD OF STEEL
SINCE 1971

THERMEX TMT (QST) | CUT N BENT TMT (QST)

SRJ PEETY STEELS PVT. LTD.
D-51/1 & D-51/2, Addl. M.I.D.C. Area,
P. O. Box No. 26, JALNA - 431 203. (M.S.)
Phone : 02482-220009 | Fax : 02482-221474
E-mail : accounts@shreeomsteels.com
Website : www.shreeomsteels.com

Annexure - 1 Para 3 of the Scheme of Testing & Inspection

Test Certificate No. Shree Om TMT (QST) 17525 Date : 14-03-2024

To M/S SURATNA INFRA LLP , JALGAON

It is certified that the material described below confirms to IS:1786:2008. Chemical Composition and Mechanical Properties of the product as tested in accordance with the scheme of Testing & Inspection contained in the ISI Certification Marks Licence No. CM/L - 734 5271 are as indicated below against each order No. etc.
(Please refer to IS:1786:2008 for details of specification requirements)

Order No. & Date	/14-03-2024			
Nominal size in mm	8MM	12MM	16MM	20MM
Lot No. / Heat No.	SOR-31/02	SOR-27/03	SOR-30/02	SOR-26/03
Quantity in M. T.	3.550	3.020	3.970	4.440
CHEMICAL ANALYSIS				
C%	0.21	0.22	0.23	0.22
Mn%	0.60	0.54	0.54	0.56
S%	0.029	0.043	0.022	0.036
P%	0.047	0.045	0.042	0.045
S+Ph%	0.076	0.088	0.064	0.081
N%	-	-	-	-
CE Value	0.31	0.31	0.32	0.31
MECHANICAL PROPERTIES				
0.2% Proof Stress N/mm² (Min.)	500.00	500.00	500.00	500.00
0.2% Proof Stress N/mm² (Max.)	557.00	559.00	536.00	560.00
Ultimate Tensil Strength N/mm²	644.00	665.00	632.00	672.00
TS/YS	1.16	1.19	1.18	1.20
Elongation%	20.00	20.00	18.00	19.00
Total Elongation%	0.00	0.00	0.00	0.00
Bend Test	OK	OK	OK	OK
Rebend Test	OK	OK	OK	OK
Grade	FE-500	FE-500	FE-500	FE-500
Remarks				

Invoice No.: 20764

Truck No.: MH-18/BG-4976

The material supplied confirms to the standard Rolling & Mass Toleration

An ISO 9001:2015 Certified Company | THERMEX | IS: 1786

SRJ Peety Steels Pvt. Ltd.

Quality Control Incharge

Scanned with CamScanner

ICON STEEL
TMT BARS

Rathi Steel & Metal Pvt. Ltd. Plot No. F-12, Phase - II, Additional M.I.D.C., Jalna - 431203. (MH) India, Mob. 9607119785. www.iconsteel.com

TEST CERTIFICATE FOR HIGH STRENGTH DEFORMED STEEL BARS AND WIRES FOR CONCRETE REINFORCEMENT ACCORDING TO IS 1786:2008.

Test Certificate No.: 10922/23 **Date:** 21/03/2024 **Invoice No.:** 11387 **Vehicle No.:** MH-20-DE-5466

To M/S : SURATNA INFRA LLP

Jalgaon

It is Certified that Material described below conforms to IS : 1786 : 2008. Chemical Composition and Mechanical Properties of the product as tested in accordance with the scheme of Testing & Inspection Contained in BIS Certification marks License No. CM/L - 7522671 as indicated below against each order no.

(PLEASE REFER TO IS : 1786 : 2008 FOR DETAILS FOR SPECIFICATION REQUIREMENTS)

TEST RESULTS

Order No. and Date	Nominal Size in MM	Lot No	Quantity in M.T.	Chemical Analysis					Mechanical Properties					Re-bend Test	Remark / Grade
				C %	S %	P %	S+P %	CE Value	0.2% Proof Stress N/mm2	Ultimate Tensile Strength N/mm2	TS/YS Ratio	Elongation %	Bend Test		
	08MM	I3-AA156	2.450	0.209	0.039	0.046	0.085	0.299	593.83	700.76	1.18	19.63	OK	OK	Fe-500 ☐
	10MM	I3-BB123	2.960	0.200	0.035	0.048	0.083	0.296	585.73	697.75	1.19	19.20	OK	OK	
	12MM	I3-CC119	1.970	0.200	0.033	0.050	0.083	0.292	591.30	702.45	1.19	18.93	OK	OK	Fe-500 ☐ DS
	16MM	I3-DD103	3.500	0.184	0.040	0.049	0.089	0.276	578.71	685.98	1.19	19.50	OK	OK	Fe-550 ☐
	20MM	I3-EE063	1.500	0.204	0.028	0.042	0.070	0.310	585.22	691.74	1.18	19.63	OK	OK	
	25MM	I3-FF047	1.490	0.200	0.036	0.048	0.084	0.309	589.58	694.62	1.18	18.96	OK	OK	Fe-550 ☑ DS

The material supplied confirms to the standard rolling and mass tolerance.

Surface defects :
a) Piping ~~Absent~~ / Present
b) Other defects ~~Absent~~ / Present

Remark : OK

THERMEX

SGS Reviewed
Name: Ashwajit Sahu
Date & Sign:
SGS India Pvt. Ltd. Nagpur
The SGS Stamp and Signature merely represents receipt of the document and SGS makes no representations as to the accuracy, adequacy and/or completeness of third party test/laboratory results responses or certifications

Rathi Steel & Metal Pvt. Ltd.

Quality Control In-charge

Scanned with CamScanner

[C-Wing Column]
(28 days)

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/157/2024 Date:- 19 MAR 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 19/03/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	19/02/2024	19/03/2024	497	22.09
2	-----do----	--do--	--do--	486	21.60
3	-----do----	--do--	--do--	449	19.96

The Testing Charges amounting to Rs.260/- + GST Rs:48/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8860984 Dated : 19/03/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

(C-Wing Column)
[7 days]

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/118/2024 Date:- 7 MAR 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 02/03/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2.
1	**M-20**	23/02/2024	02/03/2024	280	12.45
2	-----do----	--do--	--do--	278	12.36
3	-----do----	--do--	--do--	279	12.40

The Testing Charges amounting to Rs.260/- + GST Rs:48/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8860939 Dated : 02/03/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

(Basement)(A-Wing Slab)
(28 days)

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/137/2024 Date:- 14 MAR 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 12/03/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	10/02/2024	12/03/2024	405	18.00
2	-----do----	--do--	--do--	252	11.20
3	-----do----	--do--	--do--	384	17.07

The Testing Charges amounting to Rs.260/- + GST Rs:48/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8860959 Dated : 12/03/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC ★ JALGAON ★

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

(1st Floor) [A-Wing Slab]
[7 days]

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/161/2024 Date:- 26 MAR 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 22/03/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	14/03/2024	22/03/2024	278	12.36
2	-----do----	--do--	--do--	257	11.42
3	-----do----	--do--	--do--	209	9.29

The Testing Charges amounting to Rs.260/- + GST Rs:48/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8860988 Dated : 22/03/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/173/2024 Date:- 2 APR 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 01/04/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	22/03/2024	01/04/2024	378	16.80
2	-----do----	--do--	--do--	279	12.40
3	-----do----	--do--	--do--	366	16.27

The Testing Charges amounting to Rs.260/- + GST Rs:48/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8861000 Dated : 01/04/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner

C-Wing 1st slab (7 days)

Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.
Phone No. 0257/2221721. Fax No. 0257/2221719. GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/176/2024 Date:- 12 APR 2024

To,
M/s Suratna Infra LLP,
Plot No. 468,Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of **Cement Concrete Cube .**

Ref . :- Your Letters No.--- dated:- 05/04/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement concrete cubes: 150 mm x150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	**M-20**	29/03/2024	05/04/2024	364	16.18

The Testing Charges amounting to Rs.100/- + GST Rs:18/- have been received in cash.
From: M/s Suratna Infra LLP,Jalgaon.
Vide receipt No: 8861005 Dated : 05/04/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.

GOVT. POLYTECHNIC JALGAON

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

Scanned with CamScanner