

Form No. 2A
ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

Date: 02/01/2025

To,
SURATNA INFRA LLP,
468, Arihant Plaza, Bahinabai Garden Square, Jilha Peth Jalgaon-425001

Subject: Certificate for quality of materials used and quality of Construction and workmanship for the work of "Sukruti Suratna" having MahaRERA Registration Number P49900052357 being developed by Suratna Infra LLP.

Sir,
I / We Shreyas Shah have undertaken an assignment of supervision of this real estate project.

Our Responsibility

I/We are responsible for carrying out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

Input Materials, Fixtures and Fittings

I/We hereby certify that all Construction material, Fixtures and Fittings with regard to the flooring, Electrical, Sanitary fittings etc. and amenities to be provided by the Promoter in the said Project, building and the Apartment as are as per specifications mentioned in Annexure 'F', of Agreement of Sale
For those items, where no specifications have been mentioned in agreement of sale, the materials, Fixtures and Fittings used conform to the relevant BIS Standards / IS /National Building codes or as per industry standards.

Workmanship

I/we hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

Structural Engineer-


Promoters has engaged structural engineer Mr. Mohit Patil having JCMC License no. 28 & having office at Unity Chamber, Ganesh Colony Jalgaon having cell no 9967144499. The structural design of buildings in this project has been done under his supervision. The formwork and concrete mix design has been done as per IS 10262:2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record

Preservation of records

Records of all test results of this project have been properly kept in the prescribed formats and will be preserved at least up to the defect liability period or for the period as required by any other provision of law. We have attached the records of material as well as concrete testing along with this letter for your perusal.

Please specify deviation in quality of materials or any other item of work which were not conforming to the specifications as mentioned in Agreement of Sale - NA

Your Faithfully,


Signature of Engineer

Name : M/S SHREYAS SHAH

Qualification : B.E Civil (University of Pune)

Phone No. : 7020118705

Place : Jalgaon

Agreed and Accepted by:


Signature of Promoter

Name: Mr.Anish.C.Shah

Date: 02/01/2025

SURATNA INFRA LLP

OFFICE : 468 Arihant Plaza, Bahinabai Garden Square, Jilha Peth, Jalgaon 425001 Tel. 0257-2233473
Mobile 7020118705, 8275017644 E.mail : arihantdevelopers9@gmail.com



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAAGG0532Q1ZA

No: GPJ/AMD/Testing/454/2024

Date:- 8 NOV 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 07/11/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	21/10/2024	07/11/2024	520	23.11
2	----do----	--do--	--do--	273	12.13
3	M-20	22/10/2024	07/11/2024	584	25.96
4	----do----	--do--	--do--	724	32.18


The Testing Charges amounting to Rs.408/- + GST Rs:74/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861720 Dated : 07/11/2024.




Testing In Charge
Lect.in App.Mech.



Head of App.mech.Dept.
Govt. Poly. Jalgaon.





(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/447/2024

Date:- 4 NOV 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 29/10/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	22/10/2024	30/10/2024	413	18.36
2	----do----	--do--	--do--	437	19.42

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861712 Dated : 30/10/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGC0532Q1ZA

No: GPJ/AMD/Testing/448/2024

Date:- 4 NOV 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 30/10/2024.

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	16/10/2024	30/10/2024	398	17.69
2	----do----	--do--	--do--	434	19.29

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861713 Dated : 30/10/2024.

[Signature]

Testing In Charge
Lect.In App.Mech.

[Signature]

Head of App.mech.Dept.
Govt. Poly. Jalgaon.



[Signature]

(Dr. P.M.Paul)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/456/2024

Date:- 16 NOV 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 11/11/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm,

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	01/10/2024	11/11/2024	684	30.40
2	----do----	--do--	--do--	547	24.31
3	M-20	30/09/2024	11/11/2024	695	30.89
4	----do----	--do--	--do--	610	27.11


The Testing Charges amounting to Rs.408/- + GST Rs:74/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861722 Dated : 11/11/2024.



Testing In Charge
Lect.in App.Mech.



Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/463/2024

Date:- 16 NOV 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 16/11/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	16/10/2024	16/11/2024	408	18.13
2	----do----	--do--	--do--	584	25.96


The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861729 Dated : 16/11/2024.




Testing In Charge
Lect.in App.Mech.



Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M. Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/471/2024

Date:- 27 NOV 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 27/11/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	21/11/2024	27/11/2024	568	25.24
2	----do----	--do--	--do--	767	34.09
3	M-20	22/11/2024	27/11/2024	830	36.89
4	----do----	--do--	--do--	659	29.29

The Testing Charges amounting to Rs.408/- + GST Rs:74/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861737 Dated : 27/11/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/473/2024

Date:- 4 DEC 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No. — dated:- 29/11/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	21/11/2024	29/11/2024	339	15.07
2	—do—	—do—	—do—	383	17.02

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861739 Dated : 29/11/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPI/AMD/Testing/477/2024

Date:- 4 DEC 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 02/12/2024.

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	25/11/2024	02/12/2024	310	13.78
2	---do---	---do---	---do---	321	14.27

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861743 Dated : 02/12/2024.

Patil

Testing In Charge
Lect.in App.Mech.

Patil
Head of App.mech.Dept.
Govt. Poly. Jalgaon.



Patil
(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/488/2024

Date:- 11 DEC 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 06/12/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	22/11/2024	06/12/2024	398	17.69
2	----do----	--do--	--do--	402	17.87

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861754 Dated : 06/12/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dep
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/497/2024

Date:- 12 DEC 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.-- dated:- 11/12/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	04/12/2024	11/12/2024	374	16.62
2	----do----	--do--	--do--	382	16.98

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861763 Dated : 11/12/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/489/2024

Date:- 11 DEC 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 09/12/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	25/11/2024	09/12/2024	398	17.69
2	----do----	--do--	--do--	426	18.93

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861755 Dated : 09/12/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept
Govt. Poly, Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly, Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGC0532Q1ZA

No: GPI/AMD/Testing/509/2024

Date:- 19 DEC 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 18/12/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	04/12/2024	18/12/2024	490	21.78
2	----do----	--do--	--do--	405	18.00

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861775 Dated : 18/12/2024.


Testing In Charge
Lect.in App.Mech.


+ Head of App.mech.Dep
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/515-A/2024

Date:- 21 DEC 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 21/12/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	14/12/2024	21/12/2024	434	19.29
2	---do---	---do---	---do---	419	18.62

The Consolidated Testing Charges amounting to Rs.400/- + GST Rs.72/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861781 Dated : 21/12/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/515/2024

Date:- 21 DEC 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No. --- dated:- 21/12/2024,


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	22/11/2024	21/12/2024	577	25.64
2	-----do-----	--do--	--do--	560	24.89

The Consolidated Testing Charges amounting to Rs.400/- + GST Rs:72/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861781 Dated : 21/12/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/517/2024

Date:- 23 DEC 2024,

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 23/12/2024.

The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	25/11/2024	23/12/2024	393	17.47
2	----do----	--do--	--do--	434	19.29
3	M-20	16/12/2024	23/12/2024	357	15.87
4	----do----	--do--	--do--	436	19.38

The Consolidated Testing Charges amounting to Rs.400/- + GST Rs:72/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861783 Dated : 23/12/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dep
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/527/2024

Date:- 31 DEC 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No. --- dated:- 30/12/2024.

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	14/12/2024	30/12/2024	465	20.67
2	---do---	--do--	--do--	530	23.56
3	M-20	16/12/2024	30/12/2024	486	21.60
4	---do---	--do--	--do--	462	20.53

The Consolidated Testing Charges amounting to Rs.400/- + GST Rs.72/- have been received in cash.
From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861793 Dated : 30/12/2024.

[Signature]

Testing In Charge
Lect.in App.Mech.

[Signature]
Head of App.mech.Dep
Govt. Poly. Jalgaon.



[Signature]
(Dr. P.P. Chaudhari)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/14/2025

Date:- 6 JAN 2025

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 04/01/2025.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	04/12/2024	04/01/2025	616	27.38
2	---do---	---do---	---do---	535	23.78

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861812 Dated : 04/01/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.D
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon