

Form No. 2A
ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

Date: 05/09/2024

To,
SURATNA INFRA LLP,
465, Arihant Plaza, Bahinabai Garden Square, Jilha Peth Jalgaon-425001

Subject: Certificate for quality of materials used and quality of Construction and workmanship for the work of "Sakrati Suratna" having Maharashtra Registration Number P49908052357 being developed by Suratna Infra LLP.

Sir,
I - We Shreyas Shah have undertaken an assignment of supervision of this real estate project.

Our Responsibility

I/We are responsible for carrying out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

Input Materials, Fixtures and Fittings

I/We hereby certify that all Construction material, Fixtures and Fittings with regard to the flooring, Electrical, Sanitary fittings etc. and amenities to be provided by the Promoter in the said Project, building and the Apartment as are as per specifications mentioned in Annexure 'P', of Agreement of Sale.
For those items, where no specifications have been mentioned in agreement of sale, the materials, Fixtures and Fittings used conform to the relevant BIS Standards / IS /National Building codes or as per industry standards.

Workmanship

I/We hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

Structural Engineer-

Promoters has engaged structural engineer Mr. Mohit Patil having JCMC License no.28 & having office at Unity Chamber, Ganesh Colony Jalgaon having cell no 9967144499. The structural design of buildings in this project has been done under his supervision. The formwork and concrete mix design has been done as per IS 10262:2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record.

Preservation of records

Records of all test results of this project have been properly kept in the prescribed formats and will be preserved at least up to the defect liability period or for the period as required by any other provision of law. We have attached the records of material as well as concrete testing along with this letter for your perusal.

Please specify deviation in quality of materials or any other item of work which were not conforming to the specifications as mentioned in Agreement of Sale - NA

Your Faithfully,

Signature of Engineer

Name: M/S SHREYAS SHAH

Qualification : B.E Civil (University of Pune)

Phone No. : 7020118705

Place : Jalgaon

Agreed and Accepted by:

SURATNA INFRA LLP

Signature of Promoter

Name: Mr. Anish C. Shah

Date: 05/09/2024



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

Date:- 20 SEP 2024

No: GPJ/AMD/Testing/405/2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No. --- dated:- 20/09/2024.

The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	06/09/2024	20/09/2024	486	21.60
2	----do----	--do--	--do--	604	26.84

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861654 Dated : 20/09/2024.

Testing In Charge
Lect.in App.Mech.

Head of App.mech.Dept.
Govt. Poly. Jalgaon.



(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

No: GPJ/AMD/Testing/403/2024

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

Date:-

20 SEP 2024

To,
M/s Sai Infrastructure,
Plot No A-2, Near MIDC Watertank,
Khadaka-Kinhi, MIDC,
Ta. Bhusawal, Dist-Jalgaon.

Subject : Testing of AAC Block.

Ref. :- Your Letters No. --- dated:- 20/09/2024

The test results of Compressive Strength of AAC Block sent by you are as below:
Size of AAC Block : 150 mm x 150 mm x 150 mm.


Result :


Sr.No	Identification mark	Date of Casting	Date of Testing	Compressive load in KN	Stress in N/mm ²
1.	B1	--	20/09/2024	124	5.51
2	B2	--	--do--	117	5.20
3	B3	--	--do--	116	5.16
4	T1	--	20/09/2024	138	6.13
5	T2	--	--do--	126	5.60
6	T3	--	--do--	133	5.91
7	M1	--	20/09/2024	123	5.47
8	M2	--	--do--	113	5.02
9	M3	--	--do--	132	5.87

The testing charges amounting to Rs. 780/- + GST Rs: 142/- have been received in cash.

From: M/s Sai Infrastructure, Bhusawal.

Vide receipt No: 8861652 Dated : 20/09/2024


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M. Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/398/2024

Date:- 17 SEP 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 13/09/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	06/09/2024	13/09/2024	519	23.07
2	----do----	--do--	--do--	509	22.62

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861645 Dated : 13/09/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

Date:- 10 SEP 2024

No: GPJ/AMD/Testing/392/2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No. --- dated:- 09/09/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	10/08/2024	09/09/2024	358	15.91
2	----do----	--do--	--do--	545	24.22
3	M-20	31/08/2024	09/09/2024	547	24.31
4	----do----	--do--	--do--	452	20.09

The Testing Charges amounting to Rs.408/- + GST Rs:74/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861638 Dated : 09/09/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




Dr. P.M. Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG05J2Q1ZA

No: GPJ/AMD/Testing/390/2024

Date:- 6 SEP 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 04/09/2024.

The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	22/08/2024	04/09/2024	309	13.73
2	-----do-----	--do--	--do--	464	20.62

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861636 Dated : 04/09/2024.

(Signature)

Testing In Charge
Lect.in App.Mech.

(Signature)

Head of App.mech.Dept.
Govt. Poly. Jalgaon.



(Signature)

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon

05/09/2024

Certificate

This is confirm that as site incharge of Sukruti Suratna located Near Sukruti DreamHomes, Pimprala Shivar, Jalgaon for which Engg. Mohit Patil Sir is the RCC consultant, I confirm that all corrections in relation to the Steel placement & laying as shown by Engg. Mohit Patil Sir during his visit at site prior to the casting of the below mentioned slabs has been done and followed as instructed by Sir.

Kindly issue us certificates for slabs casting done for the following -

- A) A-Wing - 3rd Floor Bottom Slab
- B) C-Wing - 3rd Floor Bottom Slab
- C) B-Wing - 1st Floor Bottom Slab


05/09/24
Mr. Shreyas A. Shah

Place: Jalgaon,

Date 05.09.2024



ULTRATECH CEMENT LIMITED

(Unit: Birla White)



Office: D-7, Shastri Nagar, Jodhpur (Rajasthan)

Works: Post Kharia Khangar, Tal. Bhopalgarh, Dist. Jodhpur(Rajasthan)

TEST REPORT

For

BIRLA WHITE - Levelplast

Issue Date 10-08-2024

f. No. UTCL/BW/ 27 /2024

Week No. 27

From 01-07-2024 To 07-07-2024

Nature of sample - Levelplast

"Polymer modified curing free ready-mix plaster"

"Polymer modified curing free ready-mix plaster"			
Properties	Specification	Test Results	Test Method
Tensile Adhesion Strength (N/mm ²)			
Thickness 5 mm 7 Days	≥ 0.30	0.72	EN 1348
Thickness 5 mm 28 Days	≥ 0.65	0.84	
Thickness 10 mm 7 Days	≥ 0.30	0.76	
Thickness 10 mm 28 Days	≥ 0.65	0.88	
Setting Time (Minutes)			
10 mm Thickness	≤ 90	90	EN 196
Water Capillary Absorption, 30 Min (ml)			
7 DAYS	≤ 0.80	0.4	Karsten Tube
28 DAYS	≤ 0.80	0.3	
Compressive Strength (N/mm ²)@ 28 Days			
	≥ 10	13.6	EN 1015-11
Pot Life, Hrs			
	1:00 Hrs to 1:30 Hrs	1:26	Inhouse

Shelf Life of the product: Six months from the date of manufacturing under ideal storage condition.



RKSL

Authorized Signatory
(Dr. R K Singh, FH-R&D)



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/386/2024

Date:- 4 SEP 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 29/08/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	31/07/2024	29/08/2024	625	27.78
2	----do----	--do--	--do--	572	25.42
3	----do----	--do--	--do--	470	20.89

The Consolidated Testing Charges amounting to Rs.460/- + GST Rs:84/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861632 Dated : 29/08/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/376/2024

Date:- 20 AUG 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 17/08/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	10/08/2024	17/08/2024	419	18.62
2	----do----	--do--	--do--	424	18.84

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861618 Dated : 17/08/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/373/2024

Date:- 20 AUG 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 14/08/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	30/07/2024	14/08/2024	476	21.16

The Testing Charges amounting to Rs.100/- + GST Rs:18/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861614 Dated : 14/08/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dep
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

Date:- 28 AUG 2024

No: GPJ/AMD/Testing/382/2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 26/08/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	10/08/2024	26/08/2024	320	14.22
2	----do----	--do--	--do--	473	21.02

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861624 Dated : 26/08/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dep
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



ULTRATECH CEMENT LIMITED

(Unit: Birla White)



Office: D-7, Shastri Nagar, Jodhpur (Rajasthan)

Works: Post Kharia Khangar, Tal. Bhopalgarh, Dist. Jodhpur(Rajasthan)

TEST REPORT

For

BIRLA WHITE - Levelplast

Issue Date 16-07-2024

Ref. No. UTCL/BW/ 24 /2024

Week No. 24

From 10-06-2024 To 16-06-2024

Nature of sample - Levelplast

"Polymer modified curing free ready-mix plaster"

"Polymer modified curing free ready-mix plaster"			
Properties	Specification	Test Results	Test Method
Tensile Adhesion Strength (N/mm ²)			
Thickness 5 mm 7 Days	≥ 0.30	0.73	EN 1348
Thickness 5 mm 28 Days	≥ 0.65	0.83	
Thickness 10 mm 7 Days	≥ 0.30	0.78	
Thickness 10 mm 28 Days	≥ 0.65	0.89	
Setting Time (Minutes)			
10 mm Thickness	≤ 90	89	EN 196
Water Capillary Absorption, 30 Min (ml)			
7 DAYS	≤ 0.80	0.4	Karsten Tube
28 DAYS	≤ 0.80	0.3	
Compressive Strength (N/mm ²)@ 28 Days			
	≥ 10	13.5	EN 1015-11
Pot Life, Hrs			
	1:00 Hrs to 1:30 Hrs	1:26	Inhouse

Shelf Life of the product: Six months from the date of manufacturing under ideal storage condition.



RKSL

Authorized Signatory
(Dr. R K Singh, FH-R&D)



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/364/2024

Date:- 12 AUG 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 06/08/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	30/07/2024	06/08/2024	327	14.53
2	----do----	--do--	--do--	324	14.40
3	----do----	--do--	--do--	306	13.60

The Testing Charges amounting to Rs.260/- + GST Rs:48/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861603 Dated : 06/08/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

AAC Block

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAAGG05J2Q1ZA

No: GPJ/AMD/Testing/360/2024

Date:- 12 AUG 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of AAC Blocks.

Ref. :- Your Letters No.--- dated:- 02/08/2024.

The test results of Compressive Strength of AAC Block sent by you are as below:

Size of AAC Block: 300 mm x 200 mm x 150 mm.


C/s Area : 30cm x 20cm = 600 cm²


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	D	--	02/08/2024	249	4.15
2	E	--	--do--	211	3.52

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861199 Dated : 02/08/2024.


Testing In Charge
Lect.in App.Mech.


- Head of App.mech.Dep
Govt. Poly. Jalgaon.




(Dr. P.M. Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

Date:- 13 AUG 2024

No: GPJ/AMD/Testing/371/2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 13/08/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm^2
1	M-20	30/07/2024	13/08/2024	454	20.18
2	---do---	---do---	---do---	266	11.82

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861612 Dated : 13/08/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept
Govt. Poly. Jalgaon.




Dr. P.P. Chaudhari)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAAGG05J2Q1ZA

Date:- 13 AUG 2024

No: GPJ/AMD/Testing/369/2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 12/08/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	13/07/2024	12/08/2024	299	13.28
2	----do----	--do--	--do--	434	19.29

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861610 Dated : 12/08/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dep
Govt. Poly. Jalgaon.




Dr. P.P. Chaudhari)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.
National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG05J2QIZA

No: GPJ/AMD/Testing/357/2024

Date:- **31 JUL 2024**

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 31/07/2024.


The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
-- Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	02/07/2024	31/07/2024	888	39.47
2	----do----	--do--	--do--	816	36.27

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861195 Dated : 31/07/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dep
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

Date:- 29 JUL 2024

No: GPJ/AMD/Testing/355/2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 26/07/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	13/07/2024	26/07/2024	262	11.64
2	----do----	--do--	--do--	285	12.67

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861193 Dated : 26/07/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.
National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

Date:-

11 8 JUL 2024

No: GPJ/AMD/Testing/336/2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 16/07/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.


Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	02/07/2024	16/07/2024	599	26.62
2	-----do-----	--do--	--do--	712	31.64

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.


From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861171 Dated : 16/07/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.
National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/345/2024

Date:-

22 JUL 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 20/07/2024.

The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	13/07/2024	20/07/2024	250	11.11
2	-----do-----	--do--	--do--	232	10.31

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861182 Dated : 20/07/2024.

Attale

Testing In Charge
Lect.in App.Mech.

only

Head of App.mech.Dept
Govt. Poly. Jalgaon.



Dr. P.M. Patil

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/322/2024

Date:-

12 JUL 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 09/07/2024.

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	02/07/2024	10/07/2024	865	38.44
2	-----do-----	--do--	--do--	562	24.98

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861159 Dated : 09/07/2024.

Adithi
Testing In Charge
Lect.in App.Mech.

Sush
Head of App.mech.Dep.
Govt. Poly. Jalgaon.



Y.M.
(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

Date:- 2 JUL 2024

No: GPJ/AMD/Testing/308/2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .


Ref. :- Your Letters No.--- dated:- 26/06/2024.


The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	12/06/2024	26/06/2024	286	12.71
2	----do----	--do--	--do--	255	11.33


The Consolidated Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.
From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861143 Dated : 26/06/2024.


Testing In Charge
Lect.in App.Mech.


Head of App.mech.Dept.
Govt. Poly. Jalgaon.




(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.
E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/251/2024

Date:- 3 JUN 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 30/05/2024

The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	23/05/2024	30/05/2024	249	11.07
2	-----do-----	--do--	--do--	241	10.71

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861084 Dated : 30/05/2024.

Adhale.

Testing In Charge
Lect.in App.Mech.

Subh

Head of App.mech.Dept
Govt. Poly. Jalgaon.



Y.H.D.

(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/241/2024

Date:-

28 MAY 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref . :- Your Letters No.--- dated:- 24/05/2024

The test results of Compressive Strength of Concrete Cubes Grade **M-20** sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	25/04/2024	24/05/2024	423	18.80
2	-----do-----	--do--	--do--	398	17.69

The Testing Charges amounting to Rs.200/- + GST Rs:36/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861074 Dated : 24/05/2024.

Atthale.
Testing In Charge
Lect.in App.Mech.

Atthale
Head of App.mech.Dep.
Govt. Poly. Jalgaon.



Y.H.P.
(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon



Government Polytechnic, Jalgaon.

National Highway No.6, Jalgaon- 425001.

E-mail-govtpolyjalgaon@rediffmail.com.

Phone No. 0257/2221721.

Fax No. 0257/2221719.

GST No: 27AAAGG0532Q1ZA

No: GPJ/AMD/Testing/240/2024

Date:- 28 MAY 2024

To,
M/s Suratna Infra LLP,
Plot No. 468, Bahinabai Garden Square,
Jalgaon-425001.

Subject : Testing of Cement Concrete Cube .

Ref. :- Your Letters No.--- dated:- 21/05/2024

The test results of Compressive Strength of Concrete Cubes Grade M-20 sent by you are as below:
Size of Cement Concrete Cubes : 150 mm x 150 mm x 150 mm.

Sr.No.	Identification mark	Date of casting	Date of Testing	Compressive load in KN	Compressive stress in N/mm ²
1	M-20	06/05/2024	21/05/2024	421	18.71
2	----do----	--do--	--do--	373	16.58
3	----do----	--do--	--do--	405	18.00

The Testing Charges amounting to Rs.260/- + GST Rs:48/- have been received in cash.

From: M/s Suratna Infra LLP, Jalgaon.

Vide receipt No: 8861073 Dated : 21/05/2024.

Atthale.
Testing In Charge
Lect.in App.Mech.

sub
Head of App.mech.Dpt.
Govt. Poly. Jalgaon.



H.M.
(Dr. P.M.Patil)
Principal
Govt. Poly. Jalgaon