



# OFFICE OF THE CORPORATION OF THE CITY, NAGPUR (FIRE & EMERGENCY SERVICE)

Chhatrapati Shivaji Maharaj Prashashkiya Bhawan, Mahanagar Palika, Civil lines, Nagpur – 440 001

Ph. No.: 0712-2567777  
Fax No.: 0712-2561584

No. FES/ 3980CFO.

Date:- 07/03/2018

To,

Smt. Asha P. Patharabe & Others,  
Through POA M/s Saivas Buildcon  
Partner Shriram Manohar Kekre  
Plot No. 4, Khamla, Nagpur.

Sub: - Compliance Certificate.

Ref :- 1) Recommendation Letter No. GA/2808/FB., Date 18/03/2016  
2) Your Application Dated 30.01.2018 for Compliance certificate.

Certified that the Residential building having height 20.10 mtr., Ground to Six Floor and built up area 1474.50 Sq. Mtr. belonging to Smt. Asha P. Patharabe & Others, Through POA M/s Saivas Buildcon Partner Shriram Manohar Kekre on Plot No. 4, Khamla, Nagpur has complied with the fire prevention and safety measures in accordance with the fire prevention and life safety measures act 2006 (herein after referred as said act.)

This Compliance certificate is issued on the basis of the inspection report of Deputy Chief Fire Officer, Kalamna Fire & Emergency Service dated 27.02.2018 and certificate "A" (as per the provisions of said act 2006) dated 29/01/2018 by the Licensed Agency M/s Sagar Enterprises, (License No. MFS -LA/RF-0063, RD-0045,) regarding the compliance of the fire prevention and life safety measures on following conditions as prescribed in the said act 2006.

1. Under the Sub section (3) of section 3 it is the responsibility of the owner or the occupier as the case may, shall furnish to the Chief Fire Officer a certificate in a prescribed form twice in a year i.e in the month of January and July regarding maintenance of fire prevention and life safety measures in good repair and efficient condition as specified in sub section (1).
2. Under Sub section (4) of section 3, No person shall tamper with alter remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any other person to do so.
3. The undersigned reserve the right to add/delete or amend any recommendation deemed fit during future inspection and due to upgradation of fire fighting monitoring system of this department in intrest of life safety.
4. Any additional construction or change in use of the building or part there of shall render this certificate cancelled and invalid.
5. The owner or occupier shall pay annual fee at the rate of 1% of the minimum fees specified in schedule II as per section 11(1) and 14(4)

NAGPUR MUNICIPAL CORPORATION  
FIRE SERVICE DEPARTMENT.

  
Chief Fire Officer  
Fire & Emergency Service,  
Mpl. Corporation, Nagpur.