

RESIDENCE PROPOSED GROUND FLOOR P-LINE B/U/P AREA :					
BLOCK WING - A	I	II	III	IxIxiIxiI (SQM)	
A	1	5.147	3.900		20.07
B	1	6.150	3.050		19.09
C	1	6.300	4.716		29.71
D	1	1.750	2.260		3.95
TOTAL GROUND FLOOR P-LINE B/U/P AREA:					72.74

Wing "A" TYPICAL FLOOR PLAN (FIRST TO SEVENTH FLOOR)				
Proposed Building	Floor No.	Apartment No.	Carpet Area of Apartment	Area of Balcony Attached to Apartment
Wing "A"	1st floor	101, 201, 301, 401, 501, 601, 701	66, 1070	12, 170
	To 7th fl.	102, 202, 302, 402, 502, 602, 702	51, 7670	12, 170
		103, 203, 303, 403, 503, 603, 703	66, 1070	12, 170
		104, 204, 304, 404, 504, 604, 704	66, 1070	12, 170
		105, 205, 305, 405, 505, 605, 705	52, 2450	17, 170
		106, 206, 306, 406, 506, 606, 706	51, 6150	17, 170
		107, 207, 307, 407, 507, 607, 707	51, 6150	17, 170
		108, 208, 308, 408, 508, 608, 708	52, 2450	17, 170
Total Area >			443, 458	

Form of Statement 2 (R. No. 9 (a))		
Proposed	FLOOR NO.	Total Built up Area
Building		Floors, as per
WING-A		Construction
	2	3
	Ground Floor	7
	1st FLOOR	57
	2nd FLOOR	57
	3rd FLOOR	57
	4th FLOOR	57
	5th FLOOR	57
	6th FLOOR	57
	7th FLOOR	57
	TOTAL AREA :	411

SHEET :4/9 - WING - A

PROPOSED BUILDING PLAN FOR MULTI FAMILY DWELLING
UNIT ON K.H. NO 248/2, C.T.S. NO. 1042, SHEETNO. 550/83
WARD NO. 61, MOUZA -ZINGABAI TAKLI (CITY)
TEHSIL & DIST. NAGPUR

BELONGS TO:-
M/S IKON REMEDIES PVT. LTD. REPRESENTED THROUGH
1) MR. MAHESH S/O CHANDRABHAN KINGRANI
2) MR. RAJESH S/O CHANDRABHAN KINGRANI

OFFICE OF THE NAGPUR IMPROVEMENT TRUST
Building Permit No. SE(N)/CASE No. 0211256
Date: T.No. 2023011822
SANCTIONED
15/9/2023
Building Engineer
Nagpur Improvement Trust


- | LEGENDS - | |
|---|---|
|  | ABC FIRE EXTINGUISHER |
|  | CO2 FIRE EXTINGUISHER |
|  | FIRE PUMP |
|  | FIRE SPRINKLE - PENDENT TYPE - 68 DC |
|  | FIRE ALARM CONTROL PANEL |
|  | FIRE MANUAL CALL POINT |
|  | FIRE HOOTER WITH PA TALK BACK |
|  | FIRE HYDRANT VALVE |
|  | HR-HOSE REEL |
|  | HB-HOSE BOX |
|  | AIR RELEASE VALVE |
|  | BUTTERFLY VALVE |
|  | BALL VALVE |
|  | NRV-NON RETURN VALVE |
|  | BELLOW |
|  | Y-STRAINER |
|  | MV-MECHANICAL VENTILATION
(EXHAUST BLOWER/FAN) |
|  | FIRE HYDRANT STAND POST |
|  | FIRE SERVICE INLET |
|  | BUTTERFLY VALVE |
|  | NON RETURN VALVE |
|  | 150 NB PIPE LINE - HYDRANT |
|  | 100 NB PIPE LINE - HYDRANT |
|  | 100 NB PIPE LINE - SPRINKLER |
|  | 80 NB PIPE LINE |
|  | 50 NB PIPE LINE |
|  | 40 NB PIPE LINE |
|  | 32 NB PIPE LINE |
|  | 25 NB PIPE LINE |

TERRACE TANK DETAILS -
TERRACE TANK FOR FIRE FIGHTING
CAPACITY 02 NO. X 10 KL
(3.17 X 2.56 X 1.23 M H)

UG TANK DETAILS -
UNDERGROUND WATER TANK FOR
FIRE FIGHTING CAPACITY 50 KL
(6.00 X 4.00 X 2.08 M DEEP)

PUMP DETAILS -

- 1) MAIN PUMP 1620 LPM - 01 NO.
- 2) DIESEL PUMP 1620 LPM - 01 NO.
- 3) JOCKEY PUMP 180 LPM - 01 NO.
- 4) BOOSTER PUMP 450 LPM - 02 NO.



PLOT BOUNDARY SHOWN IN
PROPOSED CONSTRUCTION SHOWN IN

NOTE :-
ALL DIMENSIONS ARE IN METERS

Owners Name & Signature :-

M/S IKON REMEDIES PVT. LTD
REPRESENTED THROUGH:-

1)MR. MAHESH S/O CHANDRABH

2)MR. RAJESH S/O CHANDRABH

Architect Name & Signature :

SYED MOBIN ARCHITECT
Regn. No.-CA/2002/29182

NIT Survey No. 1820
NMC Lc. No.- NMC/R-263


2010/20

DRAWN

	F.R.
--	------

ARCHITECT SYED MO



PLANNING, AND
301,7/2, STYLE

(XX) NAGPUR
PHONE: (07

WEBSITE: www.sma.com
EMAIL: sma@smasolutions.com

FIRE CONSULTANT & CONTRACTOR -



M/S PREFIX ENTERPRISES
 ADD-PLOT NO.15, VAISHNA MAT,
 NAGAR, HUDKESHWAR POLICE
 STATION, PIPLA ROAD, NAGPUR
 MOB. NO. 8149977886
 Email -
prefix-enterprises@gmail.com

LICENCE NO - MFS - LA/RF-545
 LICENCE NO - MFS - LA/RD-523
 LICFNC NO - MFS - LA/PP-NII

FIRE CONSULTANT SEAL & SIGN-

PREFIX ENTERPRISES
Plot No. 5, Vaishnav Mata Mandir,
Pipla Road. Nagpur-440034
LICENCE NO : MFS-LA/RF-545
MFS-LA/BD-523

100

AUTHORISED SIGNATORY		
DESIGN BY - A.V.K	DRAWN BY - A.V.K	SHEET - 55 REV. 0

DATE - 03/07/2023	CHECKED BY- VAIBHAV G.	FF-REV-0 04 OF 09
SCALE - 1:100	APPROVED BY- VAIBHAV G.	