FORM 2A

ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

(Site supervisor's certificate)

To,

Abhishek G. Bagdi,

Partner in Shree Balaji Richland promoters,

Yavatmal

Quality Assurance Certificate

(Certificate no.1 for the quarter ending on 30/6/2019)

Subject: Certificate for quality of materials used and quality of Construction and workmanship for the work of 1 no. of Buildingof the project situated on the plot bearing Survey No.20/1/2, final plot no.22-25 demarcated by its boundaries (latitude 20°24'29.4"N & longitude 78°07'08.0"E)Godowns to the North 9m wide road to the South, plot no. 20 & 21 to the East& 9m wide road to the West of MouzePimpalgaon,Tq.& Dist. Yavatmal PIN-445001, admeasuring 836.65sq.m. area being developed by Shree Balaji Richland Promoters.

Reference: **MahaRERA Registration Number- P1000017532**

Sir,

I, Yogesh S. Meshram have undertaken an assignment of supervision of this real estate project.

**1. Our Responsibility:–**

To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ to ensure quality of work.

**1. Material Testing:-**

I have applied following mandatory checks on the basic materials, used for the construction.

**i. Cement:-**

It has been tested for its fineness, soundness, setting time, compressive strength etc. as per IS codes.

**ii. Coarse aggregate:–**

It has been tested, for deleterious materials, clay lumps, crushing value, impact value as per relevant IS codes.

**iii. Bricks:–**

They have been tested for water absorption, crushing strength etc. as per other relevant IS codes.

Scanned by CamScanner

**iv. Concrete -**

It has been tested for compressive strength for various periods as per relevant IS codes.

**v. Steel for concrete:-**

It has been tested as per IS codes for tensile strength, elongation and gauge length etc. and its results are within permissible limits.

**vi. Testing of Other materials:-**

Other materials like sand,crushed sand, floor tiles, fixtures and fittings, pipes and sanitary fittings etc. used in this project confirm to relevant IS codes.

**2. Workmanship:-**

I hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

**3. Electrical Materials and workmanship: –**

The materials used conform to the relevant IS codes.

**4. Structural engineer: –**

Promoters has engaged structural engineer Mr.Abhay V.Patilhaving License no. IIE M-116812/1having cell no.9822461251

Yours Faithfully,

**Site Supervisor**
Name: Yogesh S. Meshram
Phone no. 9923643774
Place: Yavatmal

Scanned by CamScanner