



AURANGABAD MUNICIPAL CORPORATION
FIRE BRIGAD
TELEPHONE NO-2334000-40FAX No-2331444

Outward No:AMC/FIRE /11 2/ 2017

Date :06/ 12/2017

To,
Shri:- Rajesh Laxman Paraswani & Other,
Through G.P.A. M/s. Sara Builders & Developers,
Residential Highrise Building, Plot No. 02,
Gut No. 701, Building Type A, Chikalthana
Ta & Dist. Aurangabad.

Sub:- Revise Provisional Fire NOC is issued to the Residential Highrise Building,
Plot No. 02, Gut No. 701, Building Type A, Chikalthana Ta & Dist. A.bad.

Ref : - 1) Your letter dated 02/12/2017.
2) CFO Inspection date on 06/12/2017


With Reference to the above subject Revise Provisional Fire NOC is issued to Residential Highrise Building, Plot No. 02, Gut No. 701, Building Type A, Chikalthana Ta & Dist. Aurangabad. Plot area 3716.71 sq meter. Total Built up area is 3172.60 sq.mtr. Residential Highrise Building has got Parking + 5 floors. Height of the building is 17.90 Mtr.

Owner has paid Capitation fees Rs 64/- And Residential Building Revise Provisional Noc Fees Rs 10,000/- Total Rs. 10064/- in fire brigade Receipt No.112517 date 06/12/2017.

Following Fire prevention and Fire protection & Fire Fighting measures subject to The Residential Building shall be provided.

1. 4.5/6 mtr. Open space all around the building shall be provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Overhead water tank 25000 lit capacity with the fire pump of suitable capacity for building shall be provided.
3. Fire service inlet 4 way incoming shall be provided.
4. Down Commer having outlet on all floors with hose pipe / branch shall be provided.
5. Main Staircase of Width Minum 1.50 mtr each flight width & fire Escape staircase of minum width 1.50 mtr each flight width to be provided.
6. Hose reel of 100 feet on all outlets shall be provided.
7. Fire Extinguisher of DCP / Co2/ Soda Acid / Fire Buckets of suitable capacity / quantity shall be provided.
8. Use of All piped of TATA, Zenith, APL (Applo), or I.S.I. Mark for fire Hydrant system shall be provided.
9. All the above requirements shall be carried out with prior approval from fire Brigade.

As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention&Life safety Measures Act 2006. Reference to above subject Revise Provisional Fire NOC is issued to the Shri:- Rajesh Laxman Paraswani & Other, Through G.P.A. M/s. Sara Builders & Developers, Residential Highrise Building, Plot No. 02, Gut No. 701, Building Type A, Chikalthana Ta & Dist. Aurangabad.


Officer Fire Officer
Fire Brigade
Municipal Corporation Aurangabad

Copy to:- A.D.T.P AMC, Aurangabad

NOC