

FORM-2A

ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

(Site supervisor's certificate)

To,

To,

KARDA CONSTRUCTIONS LIMITED

2nd Floor, Gulmohar Status,

Above Business Bank, Samarth Nagar,

Nashik - 422005

Quality Assurance Certificate

(Certificate no- for the quarter ending March 31,2019)

Subject: Certificate for quality of materials used and quality of Construction and workmanship for the Work of 1 No. of Building of the 4th Phase of the project situated on Sr No 45, CTS No 6823 & 6820 to the North, Sr No 8, CTS No 6826 to the South, Sr No 2, CTS No 6827 to the East and Sr No 4, Nala & DP road to the West of Division Nashik, village Deolali, Taluka Nashik, District Nashik PIN-422101 Land admeasuring —2600 sq.mts. area being developed by Karda Constructions Limited.

Reference: MahaRERA Registration Number: P51600020324

Sir,

| / We... Mr. UTTAM NAWALE ... have undertaken an assignment of supervision of this real estate project.

1. Our Responsibility: -

To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

1. Material Testing-

I/We, have applied following mandatory checks on the basic materials, used in the construction.

i. Cement-

It has been tested for its fineness, soundness, setting time, compressive strength etc. as per IS code 3535:1986 or as per other relevant IS/85/NBC

code, or as per industry standards and its results are within the permissible limits.

- ii. Coarse aggregate –
It has been tested, for deleterious materials, clay lumps, crushing value, impact value as per IS 2430:1986 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within the permissible limits.
- iii. Bricks/ blocks –
They have been tested for water absorption, crushing strength etc. as per IS 5454:1978 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within permissible limits.
- iv. Concrete / Ready-mix Concrete-
It has been tested for compressive strength for various periods as per IS 456:2000 and IS 1199 or as per other relevant IS/BS/NBC codes, as per industry standards and its results are within permissible limits.
- v. Steel for concrete-
It has been tested as per IS 2062:2011 or as per other relevant IS/BS/NBC code or as per industry standards for tensile strength, elongation and gauge length etc. and its results are within permissible limits.
- vi. Testing of Other materials –
Other materials like sand, crushed sand, floor tiles, fixtures and fittings, pipes and sanitary fittings etc. (List out all items) used in this project conform to relevant IS/BS/NBC code or as per standards laid down by the Industry for a particular material.

2. Workmanship:-

I / we hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

3. Electrical Materials and workmanship: -

Works of all the electrical wiring/ connections / lift installation / other electrical installations have been carried out under authorized /registered electrical engineer and its records has been maintained. The materials used conform to the relevant IS/ BS/ National Building codes or as per industry standards.


4. Structural engineer: -

Promoters has engaged structural engineer Mr'- '.....R.G. BIRLA.....having
Licenses no. 074..... having office
no. 201, AMAR ARCADE, NASHIK cell no 9822975229.. The
structural design of buildings in this project has been done under his
supervision. He has checked the soil report before laying PCC for foundation
in consultation with soil consultant. The formwork and concrete mix design
has been done as per IS 10262:2009 or as per other relevant codes as
applicable. His periodic checks and certificates for STABILITY and SAFETY
have been kept on record.

5. Preservation of records: -

Record of all test results of this project have been properly kept in the
prescribed formats and will be preserved at least up to the defect liability
period or for the period as required by any other provision of law

6. Please specify materials or any other item of work which were not conforming to the
standard specifications and which were not rejected



Yours Faithfully,

Signature of Engineer (Site Supervisor)

Name: -- Mr. UTTAM NAWALE

License no.(if any)-

Phone no.- 8554994706

Place: == NASHIK