i. Cement-

It has been tested for its fineness, soundness, setting time, compressive strength etc. as per IS code 3535:1986 or as per other relevant IS/85/NBC code, or as per industry standards and its results are within the permissible limits.

ii. Coarse aggregate –

It has been tested, for deleterious materials, clay lumps, crushing value, impact value as per IS 243011986 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within the permissible limits.

iii. Bricks/ blocks –

They have been tested for water absorption, crushing strength etc. as per IS 5454:1978 or as per other relevant IS/85/NBC code or as per industry standards and its results are within permissible limits.

iv. Concrete/Ready-mix Concrete-

It has been tested for compressive strength for various periods as per 15 456:2000 and IS 1199 or as per other relevant IS/BS/NBC codes, as per industry standards and its results are within permissible limits.

v. Steel for concrete-

It has been tested as per IS 2062:2011 or as per other relevant IS/BS/NBC code or as per industry standards for tensile strength, elongation and gauge length etc. and its results are within permissible limits.

vi. Testing of Other materials

Other materials like sand, crushed sand, floor tiles, fixtures and {ittings, pipes and sanitary fittings etc. (List out all items) used in this project conform to relevant IS/BS/NBC code or as per standards laid down by the Industry for a particular material.

2. <u>Workmanship:-</u>

I/ we hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

3. Electrical Materials and workmanship: –

works of all the electrical wiring/connections/lift installation/other electrical installations have been carried out under authorized/registered electrical engineer and its records has been maintained. The materials used conform to the relevant I.S/ B.S/ National Building codes or as per industry standards.

4. Structural engineer: –

Promoters has engaged structural engineer Mr. **Dattatray B. Gavhane** having Licenses no. 247. having office no .- cell no 9850509740.

Scanned by CamScanner

ER. D. B. GAVHANE B.E. (Civil)
CONSULTING CIVIL ENGINEER
+91-9850509740
shriniwasconsultant95@gmail.com

SHRINIWAS CONSULTANT

Date : 29/ 11 / 2019

FORM-2A

[See MahaRERA order no. of 2018]

ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

(site supervisor's certificate)
(To be uploaded quarterly)

Date:- 29/09/19

To,

M/S SHRI MAULI
DEVELOPERS Mr. UTTAM
SANTU DATIR (PARTNER),
MAULIKRUPA BUNGLOW, DATIR
NAGAR, OPP.NEC CLUSTER
AMBAD, NASHIK-422010.

Quality Assurance Certificate

(Certificate no 1 for the quarter ending 30 June 2019)

Subject : Certificate for quality of materials used and quality of Construction and workmanship for the Work of No. of Building(s)/Wings(s) of the **SAI MAULI APPARTMENT** Phase of the project situated on the the **Surveyt No 189/A+189/B+190+191, Plot No 24+25, Ambad Shivar, Nashik-422010** demarcated by its boundaries (latitude and longitude of the end points 12 mt colony road to the North, Plot no 26 to the South, 9.00M to the East and Plot No 22and 23 to the West of Division Nashik Village Ambad Taluka Nashik District PIN 422010 admeasuring 910.93 sq.mts. area being developed **by** M/S SHRI MAULI DEVELOPERS Mr. UTAM SANTU DATIR

Reference: MahaRERA Registration Number- P51600020480. Sir,
I/ We **Dattatray B. Gavhane** have undertaken an assignment of supervision of this real estate project.

1. Our Responsibility: –

To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and

1. Material Testing :-

I/we, have applied following mandatory checks on the basic materials, used in the construction.

1, "Atharv" Shivaji Nagar, Satpur, Nashik - 422012

Scanned by CamScanner