

FORM-2A
[See MahaRERA order no. of 2018]
ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE
(site supervisor's certificate) (To be uploaded quarterly)

To,
The Galaxy Buildcon, 6 ASA Ashwin nagar, pathardi phata, nashik (Name & address of Promoter).

Quality Assurance Certificate

(Certificate no.1 for the quarter ending 30/06/2020)

Subject : Certificate for quality of materials used and quality of Construction and workmanship for the Work of Saakar Residency No. of Building(s) 1 Wings(s) of the - Phase of the project situated on the plot bearing C. S. No./C.T.S. No./ Survey No. 298/2B Final plot no.31+32 demarcated by its boundaries (latitude and longitude of the end points) open space to the North, propoases 9 m. road to the South, plot no. 33 to the east, 9 m. road to the West of Division nashik village nashik taluka nashik District nashik PIN 422010 admeasuring 594.5 sq.mtrs. area being developed by Shriniwas Buildwell

Reference: MahaRERA Registration Number- P51600021319

Sir,

I Kaivalya Shamsundar Jagtap have undertaken an assignment of supervision of this real estate project.

1. Our Responsibility: –

To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and

1. Material Testing :-

I/we, have applied following mandatory checks on the basic materials, used in the construction.

i. Cement-

It has been tested for its fineness, soundness, setting time, compressive strength etc. as per IS code 3535:1986 or as per other relevant IS/85/NBC code, or as per industry standards and its results are within the permissible limits.

ii. Coarse aggregate –

It has been tested, for deleterious materials, clay lumps, crushing value, impact value as per IS 243011986 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within the permissible limits.

iii. Bricks/ blocks –

They have been tested for water absorption, crushing strength etc. as per IS 5454:1978 or as per other relevant IS/85/NBC code or as per industry standards and its results are within permissible limits.

iv. Concrete/Ready-mix Concrete-

It has been tested for compressive strength for various periods as per 15 456:2000 and IS 1199 or as per other relevant IS/BS/NBC codes, as per industry standards and its results are within permissible limits.

v. Steel for concrete-

It has been tested as per IS 2062:2011 or as per other relevant IS/BS/NBC code or as per industry standards for tensile strength, elongation and gauge length etc. and its results are within permissible limits.

vi. Testing of Other materials