



sawant associates

- Consulting Civil Engineer
- Structural Engineer
- Valuer

Shop No. 1, Nirman Vihar, Visa Mala, Dr. Vijnan Marg, College Road, Nashik Ph. : +91 253 2318459
Cell : 9422248115 / 9850107926 E-mail : bsawantassociates@gmail.com

01/10/03/2020

FORM- 2A

[See Maha RERA order no.@ of 2018a

ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

(site supervisor's
certificate) (To be
uploaded quarterly)

To,
VINAYAKA BUILDERS
C 11-12, City Plaza,
Old Agra Road,
Near Kalika Temple,
Nashik-02.
(Name & address of Promoter);

Quality Assurance Certificate

(Certificate no 01/BSS/01A/2019-2020 for the quarter ending
Dec 19 To Feb 20)

Subject :Certificate for quality of materials used and quality of Construction and workmanship for the Work of SAMARTH RESIDENCY No. of Building(s)/01 Wings(s) of the Phase of the project situated on the plot bearing C.S.No. /C.T.S .No./Survey No./Final plot no. 20, S. No. 222/A/1 at Ambad Shiwar demarcated by its boundaries (latitude and longitude of the end points)Pl No. 12 &13 to the North, 24.00 M Wide D.P. Road to the South, Plot No 21 to the East, to the West Pl No 19, of Division Satpur village Ambad, taluka & District Nashik, PIN 422 010. admeasuring475.00 sq.mtrs. area being developed by Vinayaka Builders

Reference: MahaRERA Registration Number-P 51600021567



sawant associates

- Consulting Civil Engineer
- Structural Engineer
- Valuer

Shop No. 1, Nirman Vihar, Vasa Mala, Dr. Vasan Marg, College Road, Nashik Ph. : +91 253 2318459
Cell : 9422248115 / 9850107026 E-mail : bsawantassociates@gmail.com

Sir,

I/We Er. B. S. Sawant have undertaken an assignment of supervision of this real estate project.

1. Our Responsibility:-

To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

1. Material Testing:-

I/we, have applied following mandatory checks on the basic materials, used in the construction.

2. Cement

It has been tested for its fineness, soundness, setting time, compressive strength etc. As per IScode 3535:1986 or as per other relevant IS/BS/NBC code, or as per industry standards and its results are within the permissible limits.

ii. Coarse aggregate -

It has been tested, for deleterious materials, clay lumps, crushing value, impact value as per IS2430:1986 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within the permissible limits.



iii **Bricks**- They have been tested for water absorption, crushing strength etc. as per IS5454:1978 or as per other relevant IS/BS/NBC code or as per industry standards and its results are within permissible limits.

iv. **Concrete** - It has been tested for compressive strength for various periods as per IS

456: 2000 and IS1199 or as per other relevant IS/BS/NBC codes, as per industry standards and its results are within permissible limits.

v. **Steel for concrete**-It has been tested as per IS2062:2011 or as per other relevant IS/BS/NBC code or as per industry standards for tensile strength, elongation and gauge length etc. and its results are within permissible limits.

vi, **Testing of Other materials** -

Other materials like sand, crushed sand, floor tiles, fixture sand fittings, pipes and sanitary fittings etc.(List out all items) used in this project conform to relevant IS/BS/NBC code or as per standards laid down by the Industry for a particular material.

2. **Workmanship:-**

I/we hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and upto the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.



sawant associates

- Consulting Civil Engineer
- Structural Engineer
- Valuer

Shop No. 1, Nirman Vihar, Vise Mala, Dr. Vijn Marg, College Road, Nashik Ph. : +91 253 2318458
Cell : 9422248115 / 9850107928 E-mail : bsawantassociates@gmail.com

3. Electrical Materials and workmanship:-

Works of all the electrical wiring/ connections / lift installation / other electrical installations have been carried out under authorized /Registered Electrical Engineer and its records has been maintained. The materials used conform to the relevant I.S/B.S/ National Building codes or as per industry standards.

4. Structural engineer:-

Promoters has engaged structural engineer Mr. B.S . Sawant Licenses no. 129 having office 1, Nirman-vihar, Visemala, College Road, Nashik -05. cell no. 94222 48115.

The structural design of buildings in this project has been done under his supervision. He has checked the soil report before laying PCC for foundation in consultation with soil consultant. The form work and concrete mixdesign has been done as per IS10262:2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record.


5. Preservation of records:-

Record of all test results of this project have been properly kept in the prescribed formats and will be preserved at least upto the defect liability period or for the period as required by any other provision of law.

3. Please specify materials or any other item of work which were not conforming to the standard specifications and which were not rejected.

- N. A.

Yours Faithfully,


Er. B.S. Sawant (B.E. Civil, F.I.V.)
Consulting Civil Engineer

Signature of Engineer (Site Supervisor)

Name: B. S. Sawant

273 License no.)

Phone no. 94222 48115.

Place: Nahik.