FORM-2A

[See MahaRERA order no. 5 of 2018]

ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

(site supervisor's certificate)

Date: 31/03/2025

To,

M/S. AMBER ENTERPRISES
Add: 413, Zest Business Spaces,
M. G. Road, Ghatkopar (E) 400 077.

Quality Assurance Certificate

(Certificate no. 3 for the quarter ending March-2025)

Subject : Certificate for quality of materials used and quality of Construction and workmanship for the Work of **"AMBER ELEGANCE"** of the project situated on the plot bearing New 25, H. No. 3/1, (old 91, H. No. 3 (pt)) demarcated by its boundaries (latitude and longitude of the end points) 19.208092 to the North and 73.085518 to the East of Division Konkan village Kanchangaon, Thakurli East, Tal. Kalyan, Dist. Thane, Maharashtra, PIN 421 201 admeasuring 1225 sq. mts. area being developed by **M/s. Amber Enterprises**.

Reference: MahaRERA Registration Number- **P51700076905**.

Sir,

I **MR. DINANATH B. JHA** have undertaken an assignment of supervision of this real estate project.

1. Our Responsibility :-

To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in-situ or in the authorized laboratory and to ensure quality of work and workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

1. Material Testing :-

I have applied following mandatory checks on the basic materials, used in the construction.

i. Cement-

It has been tested for its fineness, soundness, setting time, compressive strength etc. as per IS 269-2015 (Ultratech Cement Ltd) or as per industry standards and its results are within the permissible limits.

ii. GGBS-

It has been tested for its fineness, soundness, setting time, compressive strength etc. as per IS 16714 (JSW Cement Ltd) or as per industry standards and its results are within the permissible limits.

iii. Coarse aggregate -

It has been tested, for deleterious materials, clay lumps, crushing value, impact value as per IS 2430:1986 or as per industry standards and its results are within the permissible limits.

iv. Concrete-

It has been tested for compressive strength for various periods as per IS 456:2000 and IS 1199 or as per industry standards and its results are within permissible limits.

v. Steel for concrete-

It has been tested as per IS 1786-2008 and its results are within permissible limits.

2. Workmanship :-

I / we hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

3. Structural engineer: -

Promoters has engaged structural engineer **TECH LINE** having Licenses no. **M-146861-2** having office at **208, Central IT Park, Beside Hotel Satkar Grande, Near LBS Road, Mulund Check Naka, Wagle Estate, Thane (W)** Telephone no **022-25829388**.

The structural design of buildings in this project has been done under his supervision. He has checked the soil report before laying PCC for foundation in consultation with soil consultant. The formwork and concrete mix design has been done as per IS 10262:2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record.

5. Preservation of records: -

Record of all test results of this project have been properly kept in the prescribed formats and will be preserved at least up to the defect liability period or for the period as required by any other provision of law.

6. Please specify materials or any other item of work which were not conforming to the standard specifications and which were not rejected

None

Yours Faithfully,

D. N. JHA.

Signature of Engineer (Site Supervisor)
Name: **MR. DINANATH B. JHA**
Mob no. **9004651387**
Place: **Dombivli**