346

Form ----------

88

in replying please quote No.
and date of this letter.

MUNICIPAL CORPORATION OF GREATER MUMBAI

Intimation of Disapproval under Section 346 of the Mumbai Municipal Corporation Act, as amended up to date.

No. P-7691/2021/(3)/R/S Ward/AKURLI-R/S/337/1/New Dated- 09 August 2023

MEMORANDUM

Municipal Office,

Mumbai

To,

KANDIVALI SANGHAVI CO.OP. HOUSING SOC. LTD.

G-37, Sanghvi Apartments, Kamala Nehru Cross Road No.01, Kandivali west.

With reference to your Notice 337 (New) , letter No. 7397 dated. 17/6/2021 and the plans, Sections Specifications and description and further particulars and details of your buildings at Proposed Redevelopment of Existing Residential Building Known as KANDIVALI SANGHAVI CO.OP. HOUSING SOC. LTD. Plot bearing C.T.S No. 3, 3/1 to 38 of village Akurli and C.T.S. No. 377/A, 377/1 to 20 of Village Poisar at Kamala Nehru Cross Road No.01 Kandivali (West), Mumbai-400067. CTS/CS/FP No. 3 furnished to me under your letter, dated 17/6/2021. I have to inform you that, I cannot approve of the building or work proposed to be erected or executed, and I therefore hereby formally intimate to you, under Section 346 of the Mumbai Municipal Corporation Act as amended up to-date, my disapproval by reasons thereof :-

A: CONDITIONS TO BE COMPLIED WITH BEFORE STARTING THE WORK.

1 That the Janata Insurance Policy shall not be submitted.

2 That the work shall not be carried out between 6.00 a.m. to 10.00 p.m. only in accordance with Rule A (3) of the Noise Pollution (Regulation & Control) Rules, 2000 and the provisions of Notification issued by Ministry of Environment & Forest Dept. from time to time shall not be duly observed.

3 That this IOD shall not be used as an instrument for evicting the existing occupant without following due process of law.

4 That all the payments shall not be paid before requesting C.C.

5 That the NOC from H.E. shall not be submitted.

6 That the bore well shall not be constructed in consultation with H.E.

7 That A.E.W.W. NOC for extra water charges & Extra sewerage line charges R/S Ward shall not be paid before C.C.

8 That the Board shall not be displayed showing details of proposed work, name of owner, developer,

architect, R.C.C. consultant etc.

9 That all the requisite appointments & documents /remarks from consultants as per EODB shall not be submitted before asking for C.C.

10 That the N.O.C. of Collector (M.S.D) for royalty of excavation/filling of land not be submitted before C.C.

11 That the Regular /sanctioned /proposed lines and reservation will not be got demarcated at site through A.E. (Survey)/E.E. (T&C)/E.E.(D.P) and additional copy of plan shall not be submitted.

12 That the provisions of Rain Water Harvesting as per the design prepared by approved consultants in the field shall not be submitted before C.C. & completion to the same shall not submitted before O.C.C.

13 The self-declaration in respect of installing compositing pit/composite machine/bio mechanized system for processing wet waste generated at project site shall be submitted by developer/Builder/Owner as per circular no CHE/00024/GEN/dated 02/04/2016.

14 That all the condition in the orders of Hon'ble Supreme Court of India in SLP (Civil) No. D23708/2017 dated 15.03.2018 shall be complied with.

15 That the SWM NOC shall not be submitted before asking for C.C.

16 That the NOC from Tree Authority shall not be submitted.

17 That the requisitions of Regulation 49 of DCPR 2034 shall not be complied with and records of quality of work, verification report, etc. shall not be maintained on site till completion of the entire work.

18 That all the conditions in the NOC u.no. /0/2022/P/N/WSII Dated 13.08.2022 from SWM department obtained online in response to application under no. P-4409/2019/(202 And Other)/P/N Ward/VALNAI-SWM/1/New, dated - 12.08.2022 to transport & deposit / dump / level the C & D Waste at only designated unloading site – Survey No.126/1/A, Mauje – Sai, Taluka - Panvel – Raigadh & validity 08 May 2023 shall not be complied with.

19 That the adequate safeguards should not be employed for preventing dispersal of (dust) particles/particles through the air (or even otherwise) & adequate record shall not be maintained & uploaded for every single trip for disposal of C&D waste, at the time of loading the C&D waste in vehicle, after loading the C&D waste in the vehicle during the hauling.

20 That the construction site & landfill site shall not be inspected by the Licensed Architect /Licensed Engineer, the compliance report thereof shall not be uploaded, any breach in respect of the same will not entail the cancellation of the building permission or the IOD & the work will not be liable to be stopped immediately.

21 That the construction is being permitted with a condition that the debris shall not be deposited on pre-identified site with due consent /NOC of the land owner.

22 That C&D waste of large scale above 20 MT shall not be disposed off as per waste management plan approved online & as per construction and demolition waste management rules 2016.

23 That in the event the consent given by the disposal site owner / authority is revoked for any reasons, and/or in the event the time limit during which disposal site was available gets expired, the relevant construction activity shall not be given & till such time waste management plan/Debris management plan is amended to provide the new site for dumping the C&D waste and got approved online, construction work shall be recommenced.

24 That any officer of MCGM/Monitoring Committee shall not be entitled to inspect the record of grant of IOD, visit & inspect landfill sites, as well as, MCGM Officers/ Monitoring Committee shall not be entitled to bring to the notice of MCGM any breach in the IOD conditions. The order passed by MCGM on the reported breaches shall not be final & binding.

25 That the valid B.G. of Rs. 5,00,000/- shall not be furnished solely for the purpose of ensuring compliances of the conditions in the waste management plan/Debris management plan approved by SWM department of MCGM, till grant of full occupation certificate.

26 That the commencement certificate under section 44/69 (i) a of M.R. & T.P. act will not be obtained before starting the work.

27 That the notice in form of Appendix XV (Work Start Notice) shall not be submitted.

28 That the One time PCO charges shall not be paid before asking for C.C.

29 That the Indemnity bond indemnifying the corporation and its officers and specific clause in the sale agreement for a) Against any action pending on existing structure b) Against any legal dispute of plot, ownership C) Damages, risk, accidents etc & nuisance to occupier & neighbourhood during construction d) Against any litigation, claims, disputes arising out the proposed inadequate width of kitchen, AVS, etc. e) That more height of stilt will not be misused g) inadequate ratio of Car parking h) Deficient open spaces and future development of neighborhood shall not be submitted before CC.

30 That the requisitions of Reg. 11 , 12(4) &12(5) of DCPR 2034 shall not be complied with .

31 That the Comprehensive U/T and Indemnity bond as per EODB shall not be submitted.

32 That the No Dues Pending certificate from AE(WW) will not be submitted.

33 That the precautionary measures to avoid nuisance, dust, such as providing G.I. Sheets at plot boundaries up to reasonable height shall not be taken.

34 That the provision of Rain water harvesting as per design prepared by approved consultant in the field shall not be submitted before C.C.

35 That the owner shall include a clause in the sale agreement with the prospective buyer stating that the proposed building under reference is being constructed with deficient open space.

36 That the land affected by road set-back will not be handed over to MCGM & handing over certificate/Possession receipt from AE (Main) R/South ward will not be submitted.

37 That the NOC from the Electric supply company and MGL/GAS company will not be submitted before requesting C.C.

38 That the RUT for excess parking to be handed over to MCGM shall not be submitted in case full FSI is not consumed.

39 That the RUT from project proponent & clause shall not be incorporated in the sale agreements with the prospective buyer that they will not object to the development of the neighbouring building in future shall not be submitted.

40 That the Remarks, design, planning etc. from the MEP consultant shall not be submitted for mechanical ventilation sysyem and same shall not be made adequately accessible for maintance purpose.

41 That the Existing structure shown proposed to be demolished and/or shifted will not be demolised or necessary phase programme with agreement will not be submitted and got approved before CC

42 That Comprehensive undertaking as per EODB and the registered undertaking regarding following shall not be submitted before asking for the C.C. a) for compliance of all I.O.D. conditions. b) Mentioning that meter cabin, Stilt Portion, podium, society office, servants toilet, part/pocket terrace, fitness center, shall not be misused in future c) agreeing to pay the difference in premium paid and calculated as per revised land rates d) For the Mechanized Parking system / Car Lift shall be equipped with electric sensor devices and also proper precaution and safety majors shall be taken to avoid any mishap and maintenance of the same shall be done regularly. e)Mentioning that the area reserved for parking shall be used / utilized for the purpose of parking only) Mentioning that the clauses will be incorporated in the sale agreement of prospective buyers/members stating:- f) a. That the building under reference is deficient in open space and M.C.G.M. will not be held liable for the same in future. f) b. That the buyer / member agree for no objection for the neighborhood development with deficient open space in future f) c. That the buyer / member will not held M.C.G.M. liable for failure of mechanical Parking system / car lift in future.

43 That the Indemnity Bond indemnifying the Corporation and its officers shall not be submitted before asking for the C.C. a)against damages, risks accidents etc. to the occupiers and an undertaking regarding no nuisance during construction. b) against inconvenience caused due to installation of mechanized stack parking C)against any legal complication/matter that may arise due to ownership dispute regarding plot under reference

44 That the RUT for not to misuse the Lift machine room & Sloping roof above Pump room, Meter room, Servant toilet shall not be submitted before CC.

45 That the RUT for the back-to-back/tandem parking spaces may preferably be allotted to the same members/prospective occupier & the society shall be made aware of this arrangement.

46 That noC of SWD Department for nalla shall not be submitted

C: CONDITIONS TO BE COMPLIED BEFORE FURTHER C.C

1 That the plinth/stilt height completion certificate from Architect /Structural Engineer/Site Supervisor shall not submitted and plinth shall not be got checked by this office staff.

2 All the payments as intimated by various departments of MCGM shall not be paid.

3 That the Material testing report shall not be submitted.

4 That the monthly progress report of the work will not be submitted.

5 That the structural stability certificate through Regd. Structural engineer regarding stability of constructed plinth shall not be submitted before asking for CC beyond plinth.

6 Revalidated Janata Insurance Policy shall not be submitted.

7 That the C.C. shall not be re-endorsed.

8 That in the event setback and /or reservation is not handed over then at FCC , area equivalent to the area of Setback and /or reservation shall not be restricted till such area is handed over or as per circular issued from time to time.

9 That the N.O.C. from Civil Aviation Department will not be obtained for the proposed height of the building.

10 That the up-to-date Bank Guarantee and SWM NOC and AA&C NOC shall not be submitted.

D: GENERAL CONDITIONS TO BE COMPLIED BEFORE O.C

1 That the dust bin shall not be provided.

2 The dry and wet garbage shall not be separated and the wet garbage generated in the building shall not be treated separately on the same plot by the resident/ occupant of the building in the jurisdiction of MCGM. The necessary conditions in sale agreement to that effect also shall be incorporated by the developer.

3 That 3.00 mt. wide paved pathway upto staircase shall not be provided.

4 That the surrounding open spaces, parking spaces and terrace as per approved shall not be kept open.

5 That the name plate/board showing Plot No., Name of the Bldg. etc. shall not be displayed at a prominent place.

6 That carriage entrance shall not be provided as per design of registered structural engineer and carriage entrance fee shall not be paid.

7 That terraces, sanitary blocks, nahanis in kitchen shall not be made Water proof and same shall not be provided by method of pounding and all sanitary connections will not be leak proof and smoke test will not be done in presence of licensed plumber.

8 That final N.O.C. from concerned authorities / empanelled consultants for a. S.W.D. b. Sewerage c. Water Works d. CFO / Fire Fighting Provisions e. Tree authority f. Hydraulic Engineer g. A.A & C P Ward h. Rain water harvesting completion, i. Lift completion certificate from Lift Inspector j. MEP for AVS shall not be submitted before Occupation.

9 That Structural Engineer’s final Stability Certificate along with upto date License copy and R.C.C. design plan shall not be submitted.

10 That plans shall not be submitted along with Notice of Completion of work u/sec. 353A of M.M.C. Act for work completed on site.

11 That Site Supervisor certificate for quality of work and completion of the work shall not be submitted in prescribed format.

12 That the P.R. Card in the name of MCGM for Set Back Area and signle PRC for building shall not be submitted before O.C.C.

13 That the open spaces as per approval, parking spaces and terrace will not be kept open.

14 That the self –declaration in respect of installing compositing pit/ composite machine/ bio met anise system, for processing wet waste generated at project site shall not be submitted by developer/builder/owner as per circular No. CHE/0024/GEN dated 02/04/2016.

15 That the completion certificate for structural engineer & plans will not be submitted.

16 That the vermiculture bins for disposal of Wet Waste as per the design and specifications of organizations/ individuals specialized in this field, as per the list furnished by Solid Waste Management Department of B.M.C.shall not be provided to the satisfaction of Municipal Commissioner.

17 That Certificate certifying height of proposed building w.r.t.the Civil Aviation NOC for height clearance as per Notification issued by Ministry of Civil Aviation vide no. GSR 770(E) notified on 17 Dec 2020 shall not be submitted.

18 That the Mechanized parking system shall not be equipped with electric sensor devices and also proper precautions & Safety measures shall not be taken to avoid any mishap & the damages occurred due to

flooding in pit if any & maintenance of Mechanized parking system shall not be done regularly and registered undertaking & indemnity bond to that effect shall not be submitted.

19 That completion certificate from the rainwater harvesting consultant for effective completion and functioning of RWH system shall not be submitted and quantum of rain water harvested from the RWH completed scheme on site shall not be uploaded on RWH tab in online Auto DCR system

20 That the Structural stability of Mechanized pit type /Stack Parking system shall not be obtained from Regd. structural Engineer and registered undertaking to this effect in respect of structural stability and safety shall not be submitted.

21 That the registered undertaking indemnifying the B.M.C. and its officers against any litigation arising out of hardship to user in case of the failure of Mechanized system/nuisance due to mechanized system to the building under reference & to the adjoining wing/adjoining building shall not be submitted.

22 That the Sample agreement with prospective buyers/members shall not be submitted with clauses stating:- a) That the building under reference is deficient in open space and B.M.C. will not be held liable for the same in future, b) That the buyer /member agree for no objection for the neighbourhood development with deficient open space in future, c) That the buyer / members will not held B.M.C. liable for any failure of mechanical Parking system in future and proper precautions and safety measures shall be taken to avoid any mishap and the damages occurs due flooding in pit if any and maintenance of mechanized parking system shall be done regularly, d) That the buyer/member will not be held B.M.C. liable for any mishap due to provision of additional height of stilt for provision of 3 level stack type parking e) no complaints of whatsoever nature from prospective occupants/ buyers as regards parking spaces arrangement/Inadequate parking ratio shall not be entertained.

23 That the owner / developer shall not submit certificate under sec. 270A of MMC Act before asking BCC/Occupation certificate for any part of the building.

( ) That proper gutters and down pipes are not intended to be put to prevent water dropping from the leaves of the roof on the public street.
( ) That the drainage work generally is not intended to be executed in accordance with the Municipal requirements.

Subject to your so modifying your intention as to obviate the before mentioned objections and meet by requirements, but not otherwise you will be at liberty to proceed with the said building or work at anytime before the 8 August day of 2024 but not so as to contrivance any of the provision of the said Act, as amended as aforesaid or any rule, regulations or bye-law made under that Act at the time In force.
Your attention is drawn to the Special Instructions and Note accompanying this Intimation of Disapproval.

Executive Engineer, Building Proposals,
Zone, Wards.

SPECIAL INSTRUCTIONS

1. **THIS INTIMATION GIVES NO RIGHT TO BUILD UPON GROUND WHICH IS NOT YOUR PROPERTY.**

2. Under Section 68 of the Bombay Municipal Corporation Act, as amended, the Municipal Commissioner for Greater Mumbai has empowered the City Engineer to exercise, perform and discharge the powers, duties and functions conferred and imposed upon and vested in the Commissioner by Section 346 of the said Act.

3. Under Byelaw, No. 8 of the Commissioner has fixed the following levels :-

"Every person who shall erect as new domestic building shall cause the same to be built so that every part of the plinth shall be-

a) Not less than, 2 feet (60 cms.) above the center of the adjoining street at the nearest point at which the drain from such building can be connected with the sewer than existing or thereafter to be- laid in such street
b) Not less than 2 feet (60 cms.) Above every portion of the ground within 5 feet (160 cms.)-of such building.
c) Not less than 92 ft. ([!TownHall]) above Town Hall Datum.

4. Your attention is invited to the provision of Section 152 of the Act whereby the person liable to pay property taxes is required to give notice of erection of a new building or occupation of building which has been vacant, to the Commissioner, within fifteen days of the completion or of the occupation whichever first occurs. Thus compliance with this provision is punishable under Section 471 of the Act irrespective of the fact that the valuation of the premises will be liable to be revised under Section 167 of the Act, from the earliest possible date in the current year in which the completion on occupation is detected by the Assessor and Collector's Department.

5. Your attention if further drawn to the provision of Section 353-A about the necessary of submitting occupation certificate with a view to enable the Municipal Commissioner for Greater Mumbai to inspect your premises and to grant a permission before occupation and to leavy penalty for non-compliance under Section 471 if necessary.

6. Proposed date of commencement of work should be communicated as per requirements of Section 347 (1) (aa) of the Bombay Municipal Corporation Act.

7. One more copy of the block plan should be submitted for the Collector, Mumbai Suburbs District.

8. Necessary permission for Non-agricultural use of the land shall be obtained from the Collector Mumbai Suburban District before the work is started. The Non-agricultural assessment shall be paid at the site that may be fixed by the Collector, under the Land Revenue Code and Rules there under.

Attention is drawn to the notes Accompanying this Intimation of Disapproval.

No. EB/CE/ /BS /A/

NOTES

1) The work should not be started unless objections are complied with

2) A certified set of latest approved plans shall be displayed on site at the time of commencement the work and during the progress of the construction work.

3) Temporary permission on payment of deposit should be obtained any shed to house and store for construction purpose, Residence of workmen shall not be allowed on site. The temporary structures for storing constructional material shall be demolished before submission of building completion certificate and certificate signed by Architect submitted along with the building completion certificate.

4) Temporary sanitary accommodation on full flushing system with necessary drainage arrangement should be provided on site workers, before starting the work.

5) Water connection for constructional purpose will not be given until the hoarding is constructed and application made to the Ward Officer with the required deposit for the construction of carriage entrance, over the road side drain.

6) The owners shall intimate the Hydraulic Engineer or his representative in Wards atleast 15 days prior to the date of which the proposed construction work is taken in hand that the water existing in the compound will be utilised for their construction works and they will not use any Municipal Water for construction purposes. Failing this, it will be presume that Municipal tap water has been consumed on the construction works and bills preferred against them accordingly.

7) The hoarding or screen wall for supporting the depots of building materials shall be constructed before starting any work even though no materials may be expected to be stabled in front of the property. The scaffoldings, bricks metal, sand preps debris, etc. should not be deposited over footpaths or public street by the owner/ architect /their contractors, etc without obtaining prior permission from the Ward Officer of the area.

8) The work should not be started unless the manner in obviating all the objection is approved by this department.

9) No work should be started unless the structural design is approved.

10) The work above plinth should not be started before the same is shown to this office Sub-Engineer concerned and acknowledgement obtained from him regarding correctness of the open spaces & dimension.

11) The application for sewer street connections, if necessary, should be made simultaneously with commencement of the work as the Municipal Corporation will require time to consider alternative site to

avoid the excavation of the road an footpath.

12) All the terms and condition of the approved layout /sub-division under No. of should be adhered to and complied with.

13) No Building /Drainage Completion Certificate will be accepted non water connection granted (except for the construction purpose) unless road is constructed to the satisfaction of the Municipal Commissioner as per the provision of Section 345 of the Bombay Municipal Corporation Act and as per the terms and conditions for sanction to the layout.

14) Recreation ground or amenity open space should be developed before submission of Building Completion Certificate.

15) The access road to the full width shall be constructed in water bound macadam before commencing work and should be complete to the satisfaction of Municipal Commissioner including asphalting lighting and drainage before submission of the Building Completion Certificate.

16) Flow of water through adjoining holding or culvert, if any should be maintained unobstructed.

17) The surrounding open spaces around the building should be consolidated in Concrete having broke glass pieces at the rate of 12.5 cubic meters per 10 sq. meters below payment.

18) The compound wall or fencing should be constructed clear of the road widening line with foundation below level of bottom of road side drain without obstructing flow of rain water from adjoining holding before starting the work to prove the owner’s holding.

19) No work should be started unless the existing structures proposed to be demolished are demolished.

20) The Intimation of Disapproval is given exclusively for the purpose of enabling you to proceeds further with the arrangements of obtaining No Objection Certificate from the Housing Commissioner under Section 13 (h) (H) of the Rent Act and in the event f your proceeding with the work either without an intimation about commencing the work under Section 347(1) (aa) or your starting the work without removing the structures proposed to be removed the act shall be taken as a severe breach of the conditions under which this Intimation of Disapproval is issued and the sanctioned will be revoked and the commencement certificate granted under Section 45 of the Maharashtra Regional and Town Planning Act 1966, (12 of the Town Planning Act), will be with drawn.

21) If it is proposed to demolish the existing structures be negotiations with the tenant, under the circumstances, the work as per approved plans should not be taken up in hand unless the City Engineer is satisfied with the following:-

i. Specific plans in respect of evicting or rehousing the existing tenants on hour stating their number and the areas in occupation of each.
ii. Specifically signed agreement between you and the existing tenants that they are willing to avail or the alternative accommodation in the proposed structure at standard rent.
iii. Plans showing the phased programme of constructions has to be duly approved by this office before

starting the work so as not to contravene at any stage of construction, the Development control Rules regarding open spaces, light and ventilation of existing structure.

22) In case of extension to existing building, blocking of existing windows of rooms deriving light and its from other sides should be done first starting the work.

23) In case of additional floor no work should be start or during monsoon which will same arise water leakage and consequent nuisance to the tenants staying on the floor below.

24) The bottom of the over head storage work above the finished level of the terrace shall not be less than 1.20 Mt.and not more than 1.80 mt.

25) The work should not be started above first floor level unless the No Objection Certificate from the Civil Aviation Authorities, where necessary is obtained.

26) It is to be understood that the foundations must be excavated down to hard soil.

27) The positions of the nahanis and other appurtenances in the building should be so arranged as not to necessitate the laying of drains inside the building.

28) The water arrangement nut be carried out in strict accordance with the Municipal requirements.

29) No new well, tank, pond, cistern or fountain shall be dug or constructed without the previous permission in writing of the Municipal Commissioner for Greater Mumbai, as required in Section 381-A of the Municipal Corporation Act.

30) All gully traps and open channel drains shall be provided with right fitting mosquito proof made of wrought iron plates or hinges. The manholes of all cisterns shall be covered with a properly fitting mosquito proof hinged cast iron cap over in one piece, with locking arrangement provided with a bolt and huge screwed on highly serving the purpose of lock and the warning pipes of the rabbet pretested with screw or dome shape pieces (like a garden mari rose) with copper pipes with perfections each not exceeding1.5 mm in diameter. The cistern shall be made easily, safely and permanently accessible be providing a firmly fixed iron ladder, the upper ends of the ladder should be earmarked and extended 40 cms above the top where they are to be fixed as its lower ends in cement concrete blocks.

31) No broken bottles should be fixed over boundary walls. This prohibition refers only to broken bottles to not to the use of plane glass for coping over compound wall.

32) a Louvres should be provided as required by Bye0law No. 5 (b)
b Lintels or Arches should be provided over Door and Windows opening
c The drains should be laid as require under Section 234-1(a)
d The inspection chamber should be plastered inside and outside.

33) If the proposed additional is intended to be carried out on old foundations and structures, you will do so as your own risk.

No. P-7691/2021/(3)/R/S Ward/AKURLI-R/S/337/1/New Dated- 09 August 2023

Executive Engineer, Building Proposals
Zones …….…….. wards.

P-7691/2021/(3)/R/S Ward/AKURLI-R/S/337/1/New

Copy To :- 1. Abhijit Arun Mehta
101, Matru Vastsalya, V.P. Road

2. Asst. Commissioner R/S Ward.
3. A.E.W.W. R/S Ward,
4. Dy.A & C. Western Suburb II
5. Chief Officer, M.B.R. & R. Board R/S Ward .
6. Designated Officer, Asstt. Engg. (B. & F.) R/S Ward ,
7. The Collector of Mumbai

Digitally signed by HANUMANT SADASHIVRAO BURE
Date: 09 Aug 2023 12:11:29
Organization :Brihanmumbai Municipal Corporation
Designation :Executive Engineer