Anurag S. Agrawal
B.E. (Civil), AMIE, FIV
Civil Engineer & Contractor

FORM -2A

ENGINEER'S CERTIFICATE FOR QUALITY ASSURANCE

[Site Supervisor 's certificate]

To,
Kishor M Agrawal
Behind Devi Khadan
Akola.

Quality Assurance Certificate

[Certificate No. 02 for the Quarter ending March 2020]

Subject: Certificate for quality of materials used and quality of Construction and workmanship for the work of Building **"Ankit Silver Tower"** for **1** No. Of building of the **Only** phase of the project situated on the **plot No. 17/2 , Nazul Sheet No. 9** demarcated by its boundaries [latitude and longitude of the end points] **Main Govt. Road to the North, Service Lane to the South, Shops and Land of Dr Shrivastavji to the East, 30Ft Wide Road to the West** of Division : Akola , Taluka : Akola District Akola PIN 444001 admeasuring **1297.57 sq.mtrs.** area being developed by **Kishor M Agrawal**

Refernce : Maha RERA Registration Number-P 50100023354

Sir,

I **Anurag Agrawal** have undertaken an assignment of supervision of this real estate project.

- **Our Responsibility**

  To carry out the work in accordance with the development permission and as per the approved plan and submit certificate of supervision of work and to carry out material testing in –situ or in the authorized laboratory and to ensure quality of work and

8

workmanship as per prescribed specifications, and as per NBC and or other relevant code of practice.

- **Material Testing**

I / We ,have applied following mandatory checks on the basic materials used in the construction.

- **Cement**

It has been tested for its fineness, soundness, setting time, compressive strength etc. As per IS code 3535: 1986 or as per other relevant IS BS/ NBC code,or as par industry standards and its results are within the permissible limits.

- **Coarse aggregate**

It has been tested for deleterious materials, clay lumps, crushing value, impact value as per IS 2430:1986 or as per other relevant IS/BS/ NBC code or as per industry standards and its results are within the permissible limits.

- **Bricks /blocks-**

They have been tasted for water absorption, crushing strength etc.as per IS 5454: 1978 or as per other Relevant IS/ BS/ NBS/ code as per industry standards and its results are within permissible limits.

- **Concrete / Ready –mix concrete**

It has been tested for compressive strength for various periods as per IS 456:2000 and IS 1199 or as per industry standards and its results are within permissible limits.

- **Steel for concrete** –

It has been tested as per IS 2062:2011or as per other relevant IS/ BS/ NBC/ Code or as per indudtry standars for tensile Strengh , elongation and gauge length etc,and its results are within permissible limits.

Reg. No. AMC/14/2017

- **Testing of Other materials**

Other materials like sand ,crushed sand, floor tiles, fixtures and fitting, pipes and sanitary fittings etc used in this project conform to relevant IS/BS/NBC Code or as per standards laid down by the industry for a particular material.

2. Workmanship

I /We hereby certify that work has been carried out under our supervision. We further certify that workmanship and quality is satisfactory and up to the mark and the work has been acceptable within the permissible limits of deviations as per relevant code of practice.

3 . Electrical Materials and Workmanship:-

Work of all the electrical wiring/ connections/other electrical installations have been carried out under authorized /registered electrical engineer and its records has been maintained. The materials used conform to the relevant I.S/ B.S/ National Building codes or as per industry standards.

4. Structural engineer:-

Promoters has engaged structural engineer **Shri Shyamsundar Sadhwani of Pooja Consultant** having **Licenses no AM115206-0** having office no **0724-2410890** cell no **9823026459.**

The structural design of buildings in this project has been done under his supervision . He has checked the soil report before laying PCC for foundation in consultation with soil consultant. The formwork and concrete mix design has been done as per IS 10262:2009 or as per other relevant codes as applicable. His periodic checks and certificates for STABILITY and SAFETY have been kept on record.

Anurag Shriram Agrawal
Reg. No.: AMC/14/2017
AKOLA

5. Preservation of records:-

Record of all test results of this project have been properly kept in the prescribed formats and will be preserved at least up to the defect liability period or for the period as required by any other provision of law.

6. Please specify materials or any other item of work which were not conforming to the standard specifications and which were rejected – None of the material were rejected and none of the work were not confirming to standard specificiations

Anurag Agrawal
BE Civil, AMIE, FIV
11, Mhada Colony, Near Kidzee School,
Ramnagar, AKOLA. Mob. 94231 44398

Yours Faithfully,

Anurag Shriram Agrawal
(B.E. Civil , AMIE , FIV)
Regd No.: AMC/14/2017
H11 , Mhada Colony , Near Kidzee School ,
Ramnagar , Akola – 444001
Mob. :- 94231 44398
Email :- anurag.consultant@gmail.com